

# PUBLIC PRIVATE SCHOOL

## STATE OF FLORIDA DEPARTMENT OF HEALTH COUNTY HEALTH DEPARTMENT PUBLIC PRIVATE SCHOOL INSPECTION REPORT



Geocoded 25.692561/-80.446167

- PURPOSE:**
- ROUTINE
  - REINSPECTION
  - CONSTRUCT.
  - CHANGE OF OWNER
  - COMPLAINT
  - CONSULTATION
  - QA SURVEY
  - EPIDEMIOLOGY
  - OTHER
  - PREOPENING

**TYPE:** Public School

CENSUS	FEMALES	MALES
531	272	259

**NAME** Dante B. Fascell Elementary School

**ADDRESS** 15625 SW 80 Street **CITY** Miami

**OWNER** M-DCSB **ZIP** 33193

**PERSON IN CHARGE** Allen Breeding **PHONE** (305) 380-1901

**E-MAIL** breeding@dadeschools.net; emart@dadeschools.net

**RESULTS:**

- Satisfactory
- Incomplete
- Unsatisfactory
- OUT OF BUSINESS

**Correct Violations by**

- Next Inspection
- 8:00 AM on

BEGIN TIME	END TIME	DATE ASSESSED	POSITION #	EXISTING FACILITIES - PERMIT NUMBER
13:45	16:30	11/06/2013	67699	13-51-08215

RE-INSPECTION DATE

*As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.*

**SCHOOL SANITATION**

- |   |   |   |                               |                     |
|---|---|---|-------------------------------|---------------------|
| <input checked="" type="checkbox"/> 1. School Site          | <input checked="" type="checkbox"/> 8. Natural Ventilation    | <input checked="" type="checkbox"/> 15. Handwash Facilities | <b>LIQUID/SOLID WASTE</b>     | <b>SAFETY</b>       |
| <input checked="" type="checkbox"/> 2. Playground Equipment | <input checked="" type="checkbox"/> 9. Mechanical Ventilation | 16. Showers/Fixtures  | 21. Sewage Disposal           | 26. First Aid Kit   |
| 3. Athletic Equipment                                       | <b>SANITARY FACILITIES</b>                                    | 17. Shower Water Temp.                                      | 22. Solid Waste               | <b>FOOD</b>         |
| <b>BUILDINGS</b>  | 10. Provided/Accessible                                       | <b>WATER SUPPLY</b>   | <b>VECTOR/VERMIN CONTROL</b>  | 27. Food Insp. Rpt. |
| <input checked="" type="checkbox"/> 4. Construction         | <input checked="" type="checkbox"/> 11. Cleanliness & Repair  | 18. Installed/Operated/Maintained                           | 23. Infestation/Control       | <b>OTHER</b>        |
| <input checked="" type="checkbox"/> 5. Maintenance & Repair | 12. Toilet Facilities   | <input checked="" type="checkbox"/> 19. Drinking Fountains  | 24. Brush/Trash               | 28.                 |
| 6. Lighting/Foot-Candles                                    | 13. Separation of Sexes                                       | 20. Approved Source   | 25. Water Collection/Drainage | 29.                 |
| 7. Heating, Ventilation, A/C                                | 14. Fixture Ratio   |   |                               |                     |

**COMMENTS AND INSTRUCTIONS**

\*\*\*\*Congratulations, the school is very clean\*\*\*\*

**Violation #2** Repair or the replace damaged (broken, loose, warped) rubber floor tiles in the playground.  
**Code Reference** FAC: Playground Equipment 64E-13.004(2)(a)(c). Playgrounds shall be constructed and maintained to permit maximum utilization of sites with elimination of sanitary and health hazards including mudholes, fragments of glass, stone and similar obstructions. Fixed playground equipment shall be anchored with substantial foundations so maximum safety is obtained. Cushioning materials such as mats, wood chips, or sand shall be used under climbing equipment, slides, and swings.

**Violation #5** Repair the damaged metallic door (rusted, corroded, holes) of bathroom 017A.  
**Code Reference** FAC: Maintenance & Repair 64E-13.004(3)(b)(c). Buildings shall be kept clean and in good repair, free from hazardous conditions, such as loose or broken floor tiles and boards; loose moldings; loose hanging fixtures, pipes, and electric wires; and broken plaster. Furnishings and equipment shall be kept clean and in good repair, free of missing parts and hazards such as sharp edges, splinters, and protruding or rusty nails.

**Violation #9** Repair or replace the mechanical ventilation system of bathrooms 035B, 041B, 041C, 049B, 109B, 111B, 113B, 121B, 122B, 123B, 128B, 129B, 130B, 142A and 142B.  
**Code Reference.** Ventilation and air conditioning. FAC: 64E-13.004(5) (d). All occupied rooms and other rooms where odors or contaminants are generated shall be vented to the outside. FAC: 64E-13.004(5)(d) 2. Mechanical ventilation. All spaces which do not meet the requirements for natural ventilation shall be mechanically ventilated by means of electrically

**\*\*Continued On Page 2\*\***

**INSPECTION CONDUCTED BY:** Oswaldo Samper **PHONE:** (305) 623-3500

**INSPECTION COND SIGNATURE:** **FAX #:** \_\_\_\_\_

**COPY OF REPORT RECEIVED BY:** **DATE:** 11/6/2013

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY PUBLIC HEALTH UNIT  
Public/Private School



Name: Dante B. Fascell Elementary School

Date: 11/06/2013

Identification No: 13-51-08215

**Comments and Instructions (Continued from Page 1):**

operated exhausts. Fans and blowers shall be sized and designed to provide the required air movement without excessive or disturbing noise.

**Violation #11** Fasten to the floor and seal the base of a loose toilet fixture in bathroom 007B.

**Violation #11** Replace the missing wall tiles in bathroom 035B (repeated violation) and bathroom 071B.

**Code Reference** FAC: Cleanliness & Repair 64E-13.004(6)(a). Walls to a height of at least 4' feet toilet partitions and floor of all toilet rooms shall be finished with impervious materials. All plumbing fixtures shall conform to the provisions of the local plumbing code. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Deodorizers shall not be used in toilet rooms.

**Violation #15** Fasten the loose faucet of one hand-wash sink in bathroom 007A.

**Violation #15** Provide running water for the hand-wash sink of bathroom 034B.

**Code Reference** FAC: Handwash Facilities 64E-13.004(6)(b). Handwashing facilities shall be located within or adjoining each toilet room. Soap dispensers shall be provided at all wash basins and liquid or powdered soap shall be used. Individual towels, preferably paper shall be used. Use of common or public towels is prohibited. Hot-air hand drying devices

**Violation #19** Repair or replace one out of order drinking fountain (low water pressure) in the hallway close to custodial closet 077C.

**Code Reference** FAC: Drinking Fountains 64E-13.004(7)(b). Drinking fountains of an approved, sanitary slant jet type shall be provided in the ratio specified in the local building code or Chapter 64E-10, F.A.C. In no case shall fountains be located in any toilet room.

Copy of Report  
Received By:

A handwritten signature in black ink, appearing to read "OSVALDO SAMPER".

Inspector Osvaldo Samper