

## PUBLIC/PRIVATE SCHOOL

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC/PRIVATE SCHOOL  
INSPECTION REPORT

Geocoded 25.692561/-80.446167

- PURPOSE:  REINSPECTION  
 ROUTINE  CHANGE OF OWNER  
 CONSTRUCT.  CONSULTATION  
 COMPLAINT  EPIDEMIOLOGY  
 QA SURVEY  PREOPENING  
 OTHER

TYPE: Public School

CENSUS	FEMALES	MALES
512	248	264



## RESULTS:

- Satisfactory  
 Incomplete  
 Unsatisfactory  
 OUT OF BUSINESS

## Correct Violations by

- Next Inspection  
 8:00 AM on

NAME Dante B. Fascell Elementary SchoolADDRESS 15625 SW 80 Street CITY MiamiOWNER M-DCSB ZIP 33193PERSON IN CHARGE Margaret Ferrarone PHONE (305) 380-1901E-MAIL mdferrarone@dadeschools.net; emart@dadeschools.net

BEGIN TIME	END TIME	DATE ASSESSED	POSITION #	EXISTING FACILITIES - PERMIT NUMBER
14:20	16:00	02/20/2015	67699	13-51-08215

RE-INSPECTION DATE

As per section 120.695 of the Florida Statutes (FS), this form will serve as a "Notice of Non-Compliance: for any violations noted. Items marked below violate the requirements of Chapters 64E-13 and 64E-11 of the Florida Administrative Code (FAC) and must be corrected within the time period indicated in the "Results" section above. Continued operation of this facility without making these corrections is a violation of Chapter 64E-13 and 64E-11, FAC, and Chapter 381, FS. Failure to correct violations may result in an administrative fine or other legal action being initiated or continued.

## SCHOOL SANITATION

1. School Site  
 2. Playground Equipment  
 3. Athletic Equipment

8. Natural Ventilation  
 9. Mechanical Ventilation  
**SANITARY FACILITIES**  
 10. Provided/Accessible

15. Handwash Facilities  
 16. Showers/Fixtures  
 17. Shower Water Temp.

- LIQUID/SOLID WASTE**  
 21. Sewage Disposal  
 22. Solid Waste

- SAFETY**  
 26. First Aid Kit

## BUILDINGS

4. Construction  
 5. Maintenance & Repair  
 6. Lighting/Foot-Candles  
 7. Heating, Ventilation, A/C

11. Cleanliness & Repair  
 12. Toilet Facilities  
 13. Separation of Sexes  
 14. Fixture Ratio

- WATER SUPPLY**  
 18. Installed/Operated/  
Maintained  
 19. Drinking Fountains  
 20. Approved Source

- VECTOR/VERMIN CONTROL**  
 23. Infestation/Control  
 24. Brush/Trash  
 25. Water Collection/Drainage

- FOOD**  
 27. Food Insp. Rpt.  
**OTHER**  
 28.  
 29.

## COMMENTS AND INSTRUCTIONS

Main violations noted on the previous inspection were corrected.

**Violation #2** Repair or replace the damaged floor (several broken, loose and/or warped rubber floor tiles) of the playground. At present the playground is not in use and is kept locked.

**Code Reference** FAC: Playground Equipment 64E-13.004(2)(a)(c). Playgrounds shall be constructed and maintained to permit maximum utilization of sites with elimination of sanitary and health hazards including mudholes, fragments of glass, stone and similar obstructions. Fixed playground equipment shall be anchored with substantial foundations so maximum safety is obtained. Cushioning materials such as mats, wood chips, or sand shall be used under climbing equipment, slides, and swings.

**Violation #11** Replace two missing wall tiles behind the toilet in bathroom 035B (repeated violation).

**Code Reference** FAC: Cleanliness & Repair 64E-13.004(6)(a). Walls to a height of at least 4' feet toilet partitions and floor of all toilet rooms shall be finished with impervious materials. All plumbing fixtures shall conform to the provisions of the local plumbing code. All group toilet rooms shall be provided with at least one (1) floor drain and (1) hose bib. The floor shall be sloped to the drain. Deodorizers shall not be used in toilet rooms.

**Violation #15** Fasten the loose faucet of one hand-wash sink in bathroom 007A (repeated violation).

**Violation #15** Repair or replace the clogged soap dispenser in the handicapped accessible stall of bathroom 007B (repeated violation). There is another functional soap dispenser at the handwash sink outside the handicapped accessible stall.

**Code Reference** FAC: Handwash Facilities 64E-13.004(6)(b). Handwashing facilities shall be located within or adjoining each toilet room. Soap dispensers shall be provided at all wash basins and liquid or powdered soap shall be used. Individual towels, preferably paper shall be used. Use of common or public towels is prohibited.

INSPECTION CONDUCTED BY: Oswaldo Samper PHONE: (305) 623-3500

INSPECTION COND SIGNATURE: FAX #: \_\_\_\_\_

COPY OF REPORT RECEIVED BY: DATE: 2/20/2015

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY PUBLIC HEALTH UNIT  
Public/Private School



Name: Dante B. Fascell Elementary School

Date: 02/20/2015

Identification No: 13-51-08215

**Comments and Instructions (Continued from Page 1):**

Copy of Report  
Received By:

Inspector Osvaldo Samper

Page 2